



NOTES: UNSUITABLE SOILS ENCOUNTERED IN BOTTOM OF EXCAVATED TRENCH SHALL BE EXCAVATED & REPLACED WITH NO. 57 STONE.

ONLY SUITABLE SOIL SHALL BE USED AS BACKFILL.

WHITE COUNTY WATER AUTHORITY

DATE:	12 FEBRUARY 2002	DETAIL TITLE:	DETAIL No.
SCALE:	N.T.S.	TYPICAL DUCTILE IRON PIPE BEDDING	8:1
DRAWN BY:	SRD		